

**CITY OF MOUNTAIN VIEW  
MOUNTAIN VIEW, CALIFORNIA**

**ADDENDUM NO. 1**

**TO PLANS, CONTRACT DOCUMENTS AND SPECIFICATIONS**

**FOR**

**RENGSTORFF PARK TENNIS BLEACHER RENOVATION, PROJECT 05-40**


The following changes, additions, modifications and corrections hereinafter set forth shall apply to the Plans, Contract Documents and Specifications for this project and shall be made a part and subject to all the requirements thereof, as if originally specified and/or shown.

**NOTICE TO BIDDERS:**

1. This Addendum No. 1 contains two (2) pages, including this page.
2. Two Copies of Addendum No. 1 are enclosed.
3. These changes apply to the Technical Specifications.
4. Bidder shall attach one signed copy of this addendum to bidder's bid proposal when submitting the bid and retain the other copy for bidder's files.
5. The bid date has not been rescheduled: bids are due 3:00 p.m., May 28, 2009.

\_\_\_\_\_  
Signature of Bidder

Date: \_\_\_\_\_



\_\_\_\_\_  
Michael A. Fuller  
Assistant Public Works Director/  
City Engineer

Date: 5/22/09

## CHANGES TO CONTRACT DOCUMENTS AND SPECIFICATIONS:

1. Subsections C, "Warranty" and D, "Seating Design," on page "T3" under Section 7, "Aluminum Products," of the Technical Specifications shall be revised to read:

### "C. Warranty

The Contractor shall obtain from aluminum manufacturer and submit to City a written warranty, which guarantees, for a **minimum** period of five (5) years, all aluminum products provided against defective materials, workmanship, and welding with provisions stating that if any part of the aluminum products fail to perform as specified, intended or implied, **including footboard performing without deformation such as warping or bending**, the Manufacturer shall repair or replace that part at no additional cost to the City.

### D. Seating Design

Replacement seats and footboards shall fit the existing support structure at the bleacher, **including additional re-enforcement of the existing support structure to strengthen the seats and footboards so they will not bend or warp under loading**. In addition, the Contractor shall modify the said support structure to accommodate 6 wheelchair spaces with companion seats."

2. Subsection C, "Seat Support Structure," on page "T8" under Section 17, "Painting," of the Technical Specifications" shall be revised to read:

### "C. Seat Support Structure

Thoroughly clean and remove loose particles from the surface of the "I" beams **and columns** and tubular supports below. Apply rust-preventing type paint, such as "Rustoleum" to the surface of the prepared surface. Color for "I" beams **and columns** shall be yellow as existing. Color for tubular supports shall be determined during construction. Submit paint sample for approval."

3. A Subsection "D" shall be added to Section 17, "Painting," on page "T7" of the Technical Specifications as follows:

### "D. Trellis

Thoroughly clean and remove loose particles from the wood surfaces of the trellis and apply new paint to the wood members. Color shall be white."

## END OF ADDENDUM NO. 1